



NOTES: THE INT69 CONTACTS OPEN ON FAULT

LOW TIMER 120VAC OIL DELAY ON 30 SEC. BREAK

CONTACTS CLOSE ON LOW OIL TIME OUT

NOTES:

1. THE OIL FLOAT IS CLOSED WITH SAFE OIL LEVEL
2. THE LOW OIL TIME DELAY RELAY MUST BE WIRED TO CLOSE ITS CONTACTS ON LOW OIL TRIP OUT.
3. THE TIME DELAY AND OIL TEMP SWITCH ARE WIRED IN PARALLEL